



Test Report

2164259.02-INC

Applicant : Tekpan Teknik Elk. Kumanda Pano San.
Ve Turizm Ticaret Ltd. Sti.
Istiklal Mh. 17.Sk. No:8
Ulucak-Kemalpasa
Izmir
Turkey

Application date : 11 June 2013

Order number : 216425900-INC

Product : Busbar support

Trademark : Tekpan

Type : Adjustable Busbar Support


Arnhem, 30 October 2013

Manufacturer/ Production site: Tekpan Teknik Elk. Kumanda Pano San.
Ve Turizm Ticaret Ltd. Sti.
Istiklal Mh. 17.Sk. No:8
Ulucak-Kemalpasa
Izmir
Turkey

Subject : Fire resistance (glow-wire test) of insulating material

Test requirements : IEC 61439-1:2011 clause 10.2.3.2

Conclusion : The tested sample complies with the specified requirements

Tested by : A.A.P.M. van Vught 

Checked by : C.C. Burger 

Bur

0397-13

© DEKRA Certification B.V. All rights reserved

Products may only be provided with a quality mark or put on the market as approved if DEKRA Certification B.V. has explicitly granted the right to carry a quality mark.

DEKRA Certification B.V. and/or its subsidiaries are not liable for any direct or indirect, incidental or consequential loss originating through or because of the use of the information or data from this document or due to the impossibility of using that information or data.

The contents of this report may not be made available to a third party other than as an entity provided with the aforementioned designations with respect to copyrights and liability.